From

Assistant Divisional Fire Officer/Fire Station Officer

Panchkula

To

M/s THE GURUKUL

THE GURUKUL SECTOR 20 URBAN ESTATE PANCHKULA HARYANA

Memo No. FS/2023/150 dated: 02/06/2023

Renewal of Fire Safety Certificate Under 15 mtrs. height from the fire Safety Point of View of the Group B-Educational Building at THE GURUKUL SECTOR 20 URBAN ESTATE PANCHKULA **HARYANA of THE GURUKUL:**

Reference to you online No 130792323000275 dated 01/06/2023 on the subject cited above.

J			region office above.
Tower Name	Floor Detail	Height	Ground Coverage
BLOCK A	Stilt +3	14.31 Mtr.	388.83 Sq Mtr.
BLOCK B	GROUND + 2	12.78 Mtr.	901.868 Sq Mtr.
Basement Level	Basement A	rea Remark	(S
ONE	388.02 Sq M	tr	alamah Perdeminyan dikilahan arkang segarah di kamangan salah di Sebesah di Jangser Sebesah di Kebasah di Sebesah Se
ONE	828.55 Sq M	T.	and an artist of the second section of the second section of the second section of the second section of the second

Your site for the Renewal of the Fire Safety Certificate has been inspected by the Team of Fire Station Officers, Panchkula from fire safety Point of View. The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines.


In view of the satisfactory fire protection system / arrangement mentioned as above, this office has no objection for occupation from the Fire Safety point of view, with the following conditions:-

- The owner/occupier shall keep duly trained Fire Staff in all three shifts. 1)
- The Fire Protection System tested during inspection shall be maintained properly & always should be in good working 2) condition.
- 3) If any lapse is found in the fire protection system at the time of inspection or detected during outbreak of fire, action will be taken as per rules against you.
- You are directed to apply for Renewal of Fire Safety Certificate in future before 2 month of expiry of your Fire Safety 4)
- 5) Certificate.
 - The open set back area is not checked at our end as it shall be checked by concerned building department.
- The owner/occupier shall strictly follow the other applicable rules/ regulations/ byelaws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Section 30,31 & 47 of fire & Emergency Services Act 2022.
- You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department and video 7) graphy evidence to be kept as a record which shall be produced at the time of next Renewal; Officials/Residents/R.W.A. should be mentioned in the drill.
- If the Infringements of Byelaws remains un-noticed the Authority reserves the right to amend the Fire Safety Certificate as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- The owner or occupier of the building shall give a self-declaration certificate annually to the effect that the fire fighting system installed in his building is working in good condition and there is no addition/alteration in the building. The Fire Officer may randomly check such building. In case there is any addition/alteration beyond permissible limits under the Haryana Building Code, 2017, the fire safety certificate shall cease to exist and the owner shall apply for approval of revised Fire Fighting Scheme as per the provisions of section 18.

The above Renewal of Fire Safety Certificate is valid for Three year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.

Remarks:- As per past practice





FIRE SAFETY CERTIFICATE

No. 438/FSP	Dated: 14/6/2023
Certified that the The Gue	עאטן (name of the
building or pren	nises) at
of 02 Nos (Block-A-4 B) basement's	KULA, HARYANA (address) comprised and BLOCK - A. SHL++3 & BLOCK - G+2
(upper floors) owned/ occupied by	The GUROKUL
(name of the institution) have complied with the	fire prevention and fire safety requirements in
accordance with rule of State/ UT Fire Service Fire Service on 0.2/26/2623 (da	Rules, and verified by the officers concerned of
mr. Autar. Singh, (Adm) (name and addre	ate of inspection) in the presence of sses of the Manager/ Secretary or his
representative) and that the building/ pre	mises is fit for occupancy upto classes
(X/ XII) With effect	t from,0.2 6. 2.2.3 for a period of
conditions as appended: m renewal I was	re Noc immed Ade meno $n_0 - FS/2023/150$
	dt. 02/06/2023
2.	
3.	
4. are the second	
Issued on02/6/2023 (date of is	sue) at PANCHKULA (place) by
*Strike out whichever is not applicable.	Pindan I I la ac
Sig	nature with Seal: Find Sinch Mobile 23
Nar	ne : TARSEM SINGH
Des	signation : FIRE STATION OFFICER
Nam	e & Address of Department/ Office: FIRE STATION
То	SECTOR-S, PKL.
PRINCIPAL, THE GURUKUL,	
SEC TO R-20 (Name & Address of the Institution) PANCHE	ula.
ENDORSE	MENT
The No Objection Certificate issued by Fire S	ervice stand cancelled an annulled due to
(reasons to be recorded)	

(Name and designation of the authorized signatory)

Panchkula

^{*} The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

| Ringing | Manager | M